Desalination In Saudi Arabia An Overview


N. Nada

General Manager Desalination Nomac

Historical Background


- In 1928 King Abdul Aziz established Kendasa (Condenser) in Jeddah (MED).
- ➔ 1965 Ministry of Agriculture established desalination department.
- ➔ 1969 Duba and Alwajh desalination MSF plants commissioned 198 m3/d (52000 gpd) each.
- ➔ 1974 Saline water Conversion Corporation (SWCC) established.

Jeddah Phase 1





SWCC Plants



Daily Production In KSA

East Coast 3.722 M m³/d

West Coast 3.892 M m³/d

Total 7.614 M m³/d

2.0 BGD

Desalinated Water Distribution According to Process

RO	14%
Thermal	86%
MSF	75%
MED	11%

Basic Principal for Sea Water Intake

East Coast Shallow water -5m depth West Coast deep Water -17 m depth

Sea Water Pretreatment

RO

MSF

MED


BASIC DESALINATION ECONOMY

Coupling Desal Plants (Thermal or Membrane) with Power Plant reduces energy requirement for desalination by half.




Dual purpose plant or hybrid Power + Thermal Power + RO Power + (Thermal + RO)

Dual Purpose Plant Configuration




Dual Purpose Plant Configuration




(2) Extraction Condensing Turbine

FLOW DIAGRAM FOR DUAL PURPOSE PLANT WITH THERMAL DESALINATION PLANT




Dual Purpose Plant Configuration



(3) Condensing Turbine

Dual Purpose Plant Configuration



(4) Back Pressure Turbine + Hybridization (Thermal + RO)

Shuaibah Expansion IWPP



Shuaibah IWPP

Project cost SR 9,188 million ~ \$ 2,450 million

Power capacity 900MW (ACWA Net 270 MW)

Water capacity 880,000 M³/day (ACWA Net 264,000 M³/d)

Contract type 20 year PWPA based on BOO

PCOD 14 January 2010

ACWA Ownership 30%







Shuaibah Expansion IWPP

Project cost SAR 875 million ~ \$ 233 million

Water capacity 150,000 M³/day ACWA Net 45,000 M³/day

Contract type 20 year WPA based on BOO

PCOD November 2009

ACWA Ownership










FLOW DIAGRAM FOR DUAL PURPOSE PLANT WITH SWRO



Shuqaiq IWPP

Project cost SR 6,866 million ~ \$ 1,831 million

Power capacity 850 MW ACWA Net 289MW

Water capacity 212,000 M³/day ACWA Net 72,080 M³/d


Contract type 20 year PWPA based on BOO

Scheduled PCOD December 2010

ACWA Ownership 34%



flow diagram for SWRO



Ist Generation

Plant	Conf.	Power (MW)		Water (MGD)	P/W	Chem. Treat	TBT	Com m.		PR
J 1	LT	50	ЕСТ	5	10:1	Acid	120	1970	1980	10
Ak 1	LT	GT		5		Acid	120	1974	1982	10
J 2	LT	25	ЕСТ	5	5:1	Acid	120	1978	2007	10
J 3	СТ	62	ECT	5.8	10:1	Ad	107	1979		7
J 4	LT	120	ЕСТ	11.6	10.3:1	Ac/Ad	110	1982	2005	7
M&Y1	LT	75	ECT	6	12.5:1	Ac/Ad	120	1982		10
Job 1	СТ	60	ЕСТ	6	10:1	Ad	90	1982		8.5
Job 2	СТ	130	BPT	27.6	4.7 :1	Ad	112	1983		8.5

2nd Generation

Plant	Conf.	Power (MW)		Water (MGD)	P/W	Chem.	ТВТ	Com m	PR
Sho 1	СТ	60	ВРТ	12	5:1	Ad	102	1988	8.5
Shuq 1	СТ	80	ВРТ	15.2	5.3:1	Ad	102	1988	8.5
Sho 2	СТ	100	BPT	24	4.2:1	Ad	110	1999	9.0
M&Y2	СТ	80	BPT	18	4.4:1	Ad	110	2000	9.0

3rd Generation

Plant	Conf.	Power (MW)	Water (MGD)	P/W	Chem.	ТВТ	Comm	PR
Shoaiba 3	CT +		232.5	5.2:1	Add.	110	2009	9.5
	RO	1200						
Shuqaiq 2			57	17.9:1	Acid	-	2010	-
	RO	1020						
Marafiq	CC+CT		211	13:1	Add.	63	2010	9.5
	MED	2743						
Ras Al-	CC + CT		264	9.5:1	Add.	112	2013	9.5
Khair	+ RO	2500						

Rabigh IWSPP

Project cost

SR 4,279 million ~ \$ 1,141 million

Power capacity

360 MW ACWA Net 86MW

Water capacity

134,000 M³/day ACWA Net 32,026 M³/day

Steam capacity

1,230 t/hr ACWA Net 294 tons/hr

Contract type

25 year WECA based on BOOT

PCOD

June 2008

ACWA Ownership 23.9%






International Barges Company for Water Desalination Ltd. BOWAREGE

Project cost SR 370 million ~ USD 100 million

Water capacity 52,000 M³/day ACWA Net 33,720 M³/d)

PCOD First quarter 2008

ACWA Ownership 64.85%







Marafiq / Jubail IWPP

Project cost

SR 12,588 million ~ \$ 3,360 mil

Power capacity 2,743 MW

ACWA Net 549 MW

Water capacity

800,000 M³/day ACWA Net 160,000 M³/d

Contract type 20 year PWPA based on BOOT

Scheduled PCOD March 2010


ACWA Ownership



Marafiq / Jubail IWPP




Cogeneration Power & Water Block



9 MED Evaporators

Cogeneration Power Block



Rabigh IPP

Project cost

SR 9,397 million ~ \$ 2,506 million

Power capacity 1,204 MW ACWA Net 482MW

Contract type 20 year PPA based on BOO

Scheduled PCOD

April 2013

ACWA Ownership 40.0%





Present Desalination Practice in KSA

- 1. High Power Demand
- 2. High Water Demand

3. No Preferable Desalination Process

MSF,	MED,	RO
24MGD,	7.5MGD,	Unlimited

	MSF	MED	RO
PR	9.5	9.5	4.6 KWhr/m ³
ТВТ	112	63	
Conf.	СТ	TVC	Single & Double Pass
Size	24MGD	7.5 MGD	Unlimited

What is next?

Thermal Desalination Process

- 1- Implementation of solar energy.
- 2- Improve the performance ratio PR.
- 3- Develop high temperature antiscalant.
- 4- Reduce design fouling factor.
- 5- Improve the heat transfer coefficient.

Proposed improvement for Membrane Desalination

- 1- Improve the existing commercially viable membrane flux.
- 2- Improve salt rejection.
- **3- Resist organic fouling**.

- In 1977 an agreement between US Department of energy and KSA (KACST) was signed for the corporation in the field of solar energy to build freezing desalination plant using solar energy to produce 180 m3/d.
- The plant was built in 1985 and run for two years.

Solar Energy Water Desalination Engineering Test Facility



Solar Panels




Freezing plant consist of:


- 1-Energy collection system, 18 solar panel with total surface area 1285 m2.The design was based on local solar radiation 8.3 kwhr/m2.
- With Solar collector efficiency 65-68% steam temperature reached 389 C.
- Peak solar energy during operation 5400 kwhr/day.
- 2- Energy storage system.

- **3- Energy delivery system.**
- 4- Supplementary diesel firing system.
- **5- Desalination Plant design parameters:**
 - ➢ Daily production 180 m3/ d.
 - Sea water TDS 45000 ppm
 - Sea water temperature 35 C.
 - ➢Product water TDS < 500 ppm.</p>

Freezing Plant Flow Diagram



Freezing Plant View



Forgotten Desalination Process

- Freezing
- Advantages:
- 1- Low latent heat, energy consumption is (1/7)of the MSF or MED.
- 2- No corrosion.
- 3- No antiscalant i.e. no pretreatment.
- 4- Near atmospheric pressure.
- 5- Direct heat transfer.
- 6- High thermodynamic efficiency of refrigerant cycle.
- 7- Consistent product water quality.

Thank you